

2022-06-07 : تاريخ الطباعة :  
AM 9:05 : وقت الطباعة :  
PAC22005965 : رقم الطلب :



وزارة الداخلية  
الإدارة العامة للدفاع المدني  
إدارة الوقاية

### شهادة عدم ممانعة

نوع الشهادة : اعتماد منتج

### بيانات المنشأة

الإسم التجاري : شركة اي زد العالمي  
رقم السجل التجاري : 31686  
رقم قيد المنشأة : 12-1908-00  
البريد الإلكتروني :  
التصنيف : Passive Fire Protection System  
إسم المنتج : Fire Rated Wall / Ceiling / Floor Assemblies

### تفاصيل الشهادة

تم مراجعة الطلب المقدم واتضح بأنه لا مانع من اعتماد المنتج /المنتجات الموضحة في التقرير الفني المرفق بناء على اعتماده من قبل الهيئته المختبرية الموضحة في التقرير الفني المرفق.

### ملاحظات

1. يجب على الشركة الالتزام والعمل بما جاء في اشتراطات قسم أنظمة السلامة التي تم الاطلاع والموافقة عليها من خلال الموقع.
2. يجب ان يقوم بتركيب هذا المنتج من قبل مهندسين وفنيين معتمدين من الإدارة العامة للدفاع المدني.
3. يجب ان يحمل المنتج العلامة التجارية للهيئته المختبرية المعتمدة والموضحة في التقرير الفني المرفق.

تاريخ الاعتماد : 2022-06-06 تاريخ الإنتهاء : 2024-06-05

الإدارة العامة للدفاع المدني  
إدارة الوقاية  
مدير إدارة الاتصالات  
/٤  
(١)



DATE : 2022-06-07 : التاريخ  
PERMIT # PAC22005965 : رقم الطلب



وزارة الداخلية  
الإدارة العامة للدفاع المدني  
إدارة الوقاية

## TECHNICAL REPORT

التقرير الفني

PRODUCT	Fire Rated Wall / Ceiling / Floor Assemblies	منتج
PRODUCT APPLICATION	Passive Fire Protection System	تصنيف المعدة
APPLICANT / P.O BOX	شركه اي زد العالميه	مقدم الطلب
MANUFACTURER / LOCATION	EMAAR INDUSTRIES LLC / OMAN	الشركة المصنعة / بلد الصنع

الوصف

الموديل

Non-Loadbearing Partition Assembly comprising 50 mm thick Sandwich Panel with Mineral Wool Infill. Fire resistance rating: Up to 180 minutes (Integrity). Maximum height of the partition shall be 3000 mm, and the width can be extended without limitation.	50 mm thick Sandwich Panel w/ Mineral Wool Infill
---	---

3RD PARTY CERTIFICATE / APPROVAL	VJ097-1 Rev. 0	TBW0200830	THOMAS BELL-WRIGHT IC	شهادة المختبرات المساندة (من هيئات معتمدة)
----------------------------------	----------------	------------	-----------------------	--

RECOMMENDATIONS		التوصيات
-----------------	--	----------

### NOTES / STANDARDS

Refer to THOMAS BELL-WRIGHT IC certificate and test report for the full details.

Tested to standards BS 476 Part 20 & 22

This product approval shall comply with the NFPA 5000 (and/or other related NFPA Codes / Standards), other acceptable International Codes / Standards, Local Regulations, Listing Instructions and/or Manufacturer's Published Instructions subject to the technical review and approval of the Authority Having Jurisdiction / Qatar Civil Defence.

الإدارة العامة للدفاع المدني  
إدارة الوقاية  
/ ٤  
مدير إدارة الاتصالات

